

0	1	2	3	4
NORMAL		ABNORMAL		CRITICAL

Overall report severity based on comments.

Account Information		Component Information		Sample Information	
Account Number:	[REDACTED]	Component ID: 2020 ECODIESEL E	Tracking Number: 20150T25071		
Company Name:		Secondary ID:	Lab Number: I-133868		
Contact:		Component Type: DIESEL ENGINE	Lab Location: Indianapolis		
Address:		Manufacturer: VM MOTORI	Data Analyst: RNM		
Phone Number:		Model: 3.0 TURBO	Sampled: 19-Jul-2021		
		Application: AUTOMOTIVE	Received: 23-Jul-2021		
		Sump Capacity: 9 qt	Completed: 26-Jul-2021		
Filter Information		Miscellaneous Information		Product Information	
Filter Type: FULLFLOW			Product Manufacturer: PENNZOIL		
Micron Rating: 0			Product Name: PLATINUM EURO FULL SYNTHETIC		
			Viscosity Grade: SAE 5W40		
Comments	Flagged data does not indicate an immediate need for maintenance action. Continue to observe the trend and monitor equipment and fluid conditions. Aluminum is at a MINOR LEVEL; ALUMINUM sources in ENGINES include pistons, block and components (intake manifold, head, bearing caps), thrust bearings, main/rod bearing overlay or backing, alumina silica, or contamination from grease. Lube mixing possible due to change in additive levels; Lubricant and filter change acknowledged.				

Sample #	Wear Metals (ppm)										Contaminant Metals (ppm)			Multi-Source Metals (ppm)					Additive Metals (ppm)					
	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
1	19	1	0	13	14	0	0	0	0	0	36	4	24	0	47	0	5	1	72	21	2505	0	803	920
2	21	1	0	13	7	0	1	0	0	0	13	3	14	0	84	0	2	0	169	887	1703	0	888	1046

Sample #	Sample Information								Contaminants			Fluid Properties					
	Date Sampled	Date Received	Lube Time	Unit Time	Lube Change	Lube Added	Filter Change	Fuel Dilution	Soot	Water	Viscosity 40°C	Viscosity 100 °C	Acid Number	Base No. D4739	Oxidation	Nitration	
			mi	mi	Yes	qt	Filter Change	%	%	%	cSt	cSt	mg KOH/g	mg KOH/g	abs/cm	abs/0.1 mm	
1	19-Jun-2021	25-Jun-2021	4133	4133	Yes	9	Yes	0.6 - GC	<.1	<.1 - FTIR		13.0		8.32	9	10	
2	19-Jul-2021	23-Jul-2021	3551	7684	Yes	9	Yes	0.1 - GC	<.1	<.1 - FTIR		12.6		9.52	10	10	

Sample #	Particle Count (particles/mL)										Additional Testing	
	ISO Code Based On 4/6/14	> 4 µm	> 6 µm	> 10 µm	> 14 µm	> 21 µm	> 38 µm	> 70 µm	> 100 µm	Test Method		
1	//											
2	//											

Comments are advisory only and are based on the assumption that the sample and data submitted are valid. Results relate only to the items tested. Missing fluid or component information limits the evaluation. No warranty is expressed or implied. Measurement uncertainty available upon request.